



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08091
856-875-3506 Phone
856-875-3507 Fax

Richard F. Black Childrens Center
65 Horsehill Road
Cedar Knolls, NJ 07927
973-984-2255

www.sjwatertest.com
NJ DEP Certified Lab # 180986

Sample Location: Field Reagent Blank

Date Sampled: 04/06/22

Time Sampled: 06:30

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	U117859					
Lead	18-APR-2022 14:47	<2.00	ug/L	2.0	15.5	SM3113B
Copper	14-APR-2022 14:42	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Kitchen

Date Sampled: 04/06/22

Time Sampled: 06:30

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	U117860					
Lead	19-APR-2022 10:37	<2.00	ug/L	2.0	15.5	SM3113B
Copper	14-APR-2022 14:41	0.182	mg/L	0.05	1.3	SM3111B

Sample Location: Rm 4 - Kitchen

Date Sampled: 04/06/22

Time Sampled: 06:30

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	U117861					
Lead	18-APR-2022 14:53	<2.00	ug/L	2.0	15.5	SM3113B
Copper	14-APR-2022 14:43	0.125	mg/L	0.05	1.3	SM3111B

Sample Location: Rm 4 - Bathroom

Date Sampled: 04/06/22

Time Sampled: 06:30

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	U117862					
Lead	18-APR-2022 15:00	<2.00	ug/L	2.0	15.5	SM3113B
Copper	14-APR-2022 14:43	0.154	mg/L	0.05	1.3	SM3111B

Sample Location: Rm 5 - Kitchen

Date Sampled: 04/06/22

Time Sampled: 06:30

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	U117863					
Lead	18-APR-2022 15:06	<2.00	ug/L	2.0	15.5	SM3113B
Copper	14-APR-2022 14:44	0.070	mg/L	0.05	1.3	SM3111B

Sample Location: Water Fountain

Date Sampled: 04/06/22

Time Sampled: 06:30

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	U117864					
Lead	18-APR-2022 15:13	<2.00	ug/L	2.0	15.5	SM3113B
Copper	14-APR-2022 14:44	0.255	mg/L	0.05	1.3	SM3111B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

04/20/2022

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab # 08906

Richard F. Black Childrens Center
65 Horsehill Road
Cedar Knolls, NJ 07927
973-984-2255

Sample Location: Water Fountain Date Sampled: 04/06/22 Time Sampled: 06:30

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	U117865					
Lead	18-APR-2022 15:20	<2.00	ug/L	2.0	15.5	SM3113B
Copper	14-APR-2022 14:44	0.216	mg/L	0.05	1.3	SM3111B

Sample Location: Desk Bathroom Date Sampled: 04/06/22 Time Sampled: 06:30

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	U117866					
Lead	18-APR-2022 15:26	<2.00	ug/L	2.0	15.5	SM3113B
Copper	14-APR-2022 14:45	0.175	mg/L	0.05	1.3	SM3111B

Sample Location: Rm. 2 - Bathroom Date Sampled: 04/06/22 Time Sampled: 06:30

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	U117867					
Lead	18-APR-2022 15:33	<2.00	ug/L	2.0	15.5	SM3113B
Copper	14-APR-2022 14:46	0.174	mg/L	0.05	1.3	SM3111B

Sample Location: Rm 2 - Kitchen Date Sampled: 04/06/22 Time Sampled: 06:30

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	U117868					
Lead	19-APR-2022 10:57	<2.00	ug/L	2.0	15.5	SM3113B
Copper	14-APR-2022 14:46	0.076	mg/L	0.05	1.3	SM3111B

Sample Location: Rm 1 - Kitchen Date Sampled: 04/06/22 Time Sampled: 06:30

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	U117869					
Lead	19-APR-2022 11:03	<2.00	ug/L	2.0	15.5	SM3113B
Copper	14-APR-2022 14:47	0.071	mg/L	0.05	1.3	SM3111B

Sample Location: Rm 18 - Kitchen Date Sampled: 04/06/22 Time Sampled: 06:30

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	U117870					
Lead	19-APR-2022 11:10	<2.00	ug/L	2.0	15.5	SM3113B
Copper	14-APR-2022 14:47	0.067	mg/L	0.05	1.3	SM3111B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

04/20/2022

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Home
856-875-3507 Fax

Richard F. Black Childrens Center
65 Horsehill Road
Cedar Knolls, NJ 07927
973-984-2255

www.sjwatertest.com
NJ DEP Certified Lab # 080066

Sample Location: Rm 18 - Bathroom

Date Sampled: 04/06/22

Time Sampled: 06:30

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	U117871					
Lead	19-APR-2022 11:16	<2.00	ug/L	2.0	15.5	SM3113B
Copper	14-APR-2022 14:48	0.140	mg/L	0.05	1.3	SM3111B

Sample Location: Rm 15 - Kitchen

Date Sampled: 04/06/22

Time Sampled: 06:30

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	U117872					
Lead	19-APR-2022 11:23	<2.00	ug/L	2.0	15.5	SM3113B
Copper	14-APR-2022 14:48	0.069	mg/L	0.05	1.3	SM3111B

Sample Location: Rm 14 - Kitchen

Date Sampled: 04/06/22

Time Sampled: 06:30

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	U117873					
Lead	19-APR-2022 11:29	<2.00	ug/L	2.0	15.5	SM3113B
Copper	14-APR-2022 14:48	0.109	mg/L	0.05	1.3	SM3111B

Sample Location: Rm 13 - Bathroom

Date Sampled: 04/06/22

Time Sampled: 06:30

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	U117874					
Lead	19-APR-2022 11:36	<2.00	ug/L	2.0	15.5	SM3113B
Copper	14-APR-2022 14:49	0.144	mg/L	0.05	1.3	SM3111B

Sample Location: Rm 13 - Kitchen

Date Sampled: 04/06/22

Time Sampled: 06:30

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	U117875					
Lead	19-APR-2022 11:56	<2.00	ug/L	2.0	15.5	SM3113B
Copper	14-APR-2022 14:49	0.112	mg/L	0.05	1.3	SM3111B

Sample Location: Water Fountain

Date Sampled: 04/06/22

Time Sampled: 06:30

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	U117876					
Lead	19-APR-2022 12:02	<2.00	ug/L	2.0	15.5	SM3113B
Copper	14-APR-2022 14:49	0.742	mg/L	0.05	1.3	SM3111B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

04/20/2022

Date



**South Jersey
Water Test, LLC**
1077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab # 08096

Richard F. Black Childrens Center
65 Horsehill Road
Cedar Knolls, NJ 07927
973-984-2255

Sample Location: Water Fountain Date Sampled: 04/06/22 Time Sampled: 06:30

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	U117877					
Lead	19-APR-2022 13:15	<2.00	ug/L	2.0	15.5	SM3113B
Copper	14-APR-2022 14:50	0.639	mg/L	0.05	1.3	SM3111B

Sample Location: Rm 12 - Bathroom Date Sampled: 04/06/22 Time Sampled: 06:30

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	U117878					
Lead	19-APR-2022 12:09	3.03	ug/L	2.0	15.5	SM3113B
Copper	14-APR-2022 14:52	0.592	mg/L	0.05	1.3	SM3111B

Sample Location: Rm 12 - Kitchen Date Sampled: 04/06/22 Time Sampled: 06:30

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	U117879					
Lead	19-APR-2022 12:15	11.30	ug/L	2.0	15.5	SM3113B
Copper	14-APR-2022 14:52	0.125	mg/L	0.05	1.3	SM3111B

Sample Location: Rm 11 - Kitchen Date Sampled: 04/06/22 Time Sampled: 06:30

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	U117880					
Lead	19-APR-2022 12:22	<2.00	ug/L	2.0	15.5	SM3113B
Copper	14-APR-2022 14:52	0.096	mg/L	0.05	1.3	SM3111B

Sample Location: Rm 8 - Kitchen Date Sampled: 04/06/22 Time Sampled: 06:30

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	U117881					
Lead	19-APR-2022 12:28	<2.00	ug/L	2.0	15.5	SM3113B
Copper	14-APR-2022 14:53	0.100	mg/L	0.05	1.3	SM3111B

Sample Location: Rm 8 - Kitchen (HW) Date Sampled: 04/06/22 Time Sampled: 06:30

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	U117882					
Lead	19-APR-2022 12:35	<2.00	ug/L	2.0	15.5	SM3113B
Copper	14-APR-2022 14:53	<0.050	mg/L	0.05	1.3	SM3111B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

04/20/2022

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Richard F. Black Childrens Center
65 Horsehill Road
Cedar Knolls, NJ 07927
973-984-2255

www.sjwatertest.com
NJ DEP Certified Lab # 05006

Sample Location: Rm 20 - Kitchen Date Sampled: 04/06/22 Time Sampled: 06:30

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	U117883					
Lead	19-APR-2022 12:42	<2.00	ug/L	2.0	15.5	SM3113B
Copper	14-APR-2022 14:54	0.097	mg/L	0.05	1.3	SM3111B

Sample Location: Rm 10 - Kitchen (HW) Date Sampled: 04/06/22 Time Sampled: 06:30

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	U117884					
Lead	19-APR-2022 12:48	<2.00	ug/L	2.0	15.5	SM3113B
Copper	14-APR-2022 14:54	0.133	mg/L	0.05	1.3	SM3111B

Sample Location: Rm 9 - Kitchen Date Sampled: 04/06/22 Time Sampled: 06:30

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	U117885					
Lead	19-APR-2022 12:55	<2.00	ug/L	2.0	15.5	SM3113B
Copper	14-APR-2022 14:55	0.167	mg/L	0.05	1.3	SM3111B

Sample Location: Rm 9 - Bathroom Date Sampled: 04/06/22 Time Sampled: 06:30

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	U117886					
Lead	19-APR-2022 13:34	<2.00	ug/L	2.0	15.5	SM3113B
Copper	14-APR-2022 14:56	0.144	mg/L	0.05	1.3	SM3111B

Sample Location: Rm 7 - Kitchen Date Sampled: 04/06/22 Time Sampled: 06:30

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	U117887					
Lead	19-APR-2022 13:41	<2.00	ug/L	2.0	15.5	SM3113B
Copper	14-APR-2022 14:56	0.073	mg/L	0.05	1.3	SM3111B

Sample Location: Rm 7 - Bathroom Date Sampled: 04/06/22 Time Sampled: 06:30

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	U117888					
Lead	19-APR-2022 13:47	<2.00	ug/L	2.0	15.5	SM3113B
Copper	14-APR-2022 14:56	0.053	mg/L	0.05	1.3	SM3111B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

04/20/2022

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08091
856-875-3506 Phone
856-875-3507 Fax

www.sjwaterlab.com
NJ DEP Certified Lab # 08006

Richard F. Black Childrens Center
65 Horsehill Road
Cedar Knolls, NJ 07927
973-984-2255

Sample Location: Rm 6 - Kitchen

Date Sampled: 04/06/22

Time Sampled: 06:30

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	U117889					
Lead	19-APR-2022 13:54	<2.00	ug/L	2.0	15.5	SM3113B
Copper	14-APR-2022 14:57	0.081	mg/L	0.05	1.3	SM3111B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

04/20/2022

Date