

LABORATORY REPORT

Morristown Medical Center
100 Madison Avenue
Morristown, NJ 07962
Client #7292

REPORT NO.: 23-2927441
SAMPLE DATE: 04-12-2023
REPORT DATE: 06-19-2023
FIELD ENGINEER: Janna Cohen

SUMMARY:

According to the attached Laboratory Report from New England Testing Laboratory, results are as follows:

#	Sample Name	Copper (ug/L) EPA MCL 1300**	Lead (ug/L) EPA MCL 15**
1A	Rm 30	1.2	<0.50
2A	Rm 29 Bath	1.4	<0.50
3A	Kitchen 29/30	<1.0	<0.50
4A	Rm 27 Bath	1.3	<0.50
5A	Kitchen 27/28	<1.0	<0.50
6A	Rm 28	1.4	<0.50
7A	Kitchen 24/25	<1.0	<0.50
8A	Rm 24	1.0	<0.50
9A	Kitchen 21/22	<1.0	<0.50
10A	Rm 21/22 Bath	3.1	<0.50
11A	Rm 18/19 Bath	3.5	<0.50
12A	Rm 16/17	<1.0	<0.50
13A	Kitchen 17/18	<1.0	<0.50
14A	Rm 18 Bath	3.5	<0.50
15A	Rm 17 Bathroom	3.8	<0.50
16A	Rm 17/18 Bath	4.4	<0.50
17A	Staff Lounge 17A	1.1	<0.50
18A	Staff Lounge Bath 13A	4.5	<0.50
19A	Kitchen 3	1.4	<0.50
20A	Kitchen 2	1.1	<0.50
21A	Kitchen 1	1.0	<0.50
22A	Staff Bath Female	2.1	<0.50
23A	Staff Bath Male	<1.0	<0.50
24A	Section Rm 002	<1.0	<0.50
25A	Sick Kids Bathroom	1.6	<0.50

**EPA MCL - Maximum Contamination Limit (Primary Drinking Water Standard)

Approved by: Cara Johnson

A handwritten signature in cursive script that reads "Nora Rothschild".

Nora Rothschild, Vice President, Environmental Group