



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Richard F. Black Childrens Center
65 Horsehill Road
Cedar Knolls, NJ 07927
973-984-2255

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Field Reagent Blank

Date Sampled: 09/05/24

Time Sampled: 09:46

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142033					
Lead	9-SEP-2024 12:25	<2.00	ug/L	2.0	15.5	SM3113B
Copper	9-SEP-2024 13:03	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Kitchen

Date Sampled: 09/05/24

Time Sampled: 09:47

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142034					
Lead	9-SEP-2024 12:45	<2.00	ug/L	2.0	15.5	SM3113B
Copper	9-SEP-2024 13:01	0.240	mg/L	0.05	1.3	SM3111B

Sample Location: RM 5

Date Sampled: 09/05/24

Time Sampled: 09:50

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142035					
Lead	9-SEP-2024 13:11	<2.00	ug/L	2.0	15.5	SM3113B
Copper	9-SEP-2024 13:04	0.105	mg/L	0.05	1.3	SM3111B

Sample Location: RM 4

Date Sampled: 09/05/24

Time Sampled: 09:48

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142036					
Lead	9-SEP-2024 13:17	<2.00	ug/L	2.0	15.5	SM3113B
Copper	9-SEP-2024 13:04	0.055	mg/L	0.05	1.3	SM3111B

Sample Location: RM 4T

Date Sampled: 09/05/24

Time Sampled: 09:48

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142037					
Lead	9-SEP-2024 13:24	<2.00	ug/L	2.0	15.5	SM3113B
Copper	9-SEP-2024 13:05	0.062	mg/L	0.05	1.3	SM3111B

Sample Location: RM 5T

Date Sampled: 09/05/24

Time Sampled: 09:50

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142038					
Lead	9-SEP-2024 13:30	<2.00	ug/L	2.0	15.5	SM3113B
Copper	9-SEP-2024 13:06	0.056	mg/L	0.05	1.3	SM3111B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

09/11/2024

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Richard F. Black Childrens Center
65 Horsehill Road
Cedar Knolls, NJ 07927
973-984-2255

Sample Location: RM 15

Date Sampled: 09/05/24

Time Sampled: 10:10

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142039					
Lead	9-SEP-2024 13:37	<2.00	ug/L	2.0	15.5	SM3113B
Copper	9-SEP-2024 13:06	0.055	mg/L	0.05	1.3	SM3111B

Sample Location: R 18

Date Sampled: 09/05/24

Time Sampled: 10:10

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142040					
Lead	9-SEP-2024 13:44	<2.00	ug/L	2.0	15.5	SM3113B
Copper	9-SEP-2024 13:07	0.052	mg/L	0.05	1.3	SM3111B

Sample Location: R 13T

Date Sampled: 09/05/24

Time Sampled: 10:10

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142041					
Lead	9-SEP-2024 14:03	<2.00	ug/L	2.0	15.5	SM3113B
Copper	9-SEP-2024 13:07	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: R 14

Date Sampled: 09/05/24

Time Sampled: 10:08

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142042					
Lead	9-SEP-2024 14:10	<2.00	ug/L	2.0	15.5	SM3113B
Copper	9-SEP-2024 13:07	0.116	mg/L	0.05	1.3	SM3111B

Sample Location: RM 9T

Date Sampled: 09/05/24

Time Sampled: 10:00

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142043					
Lead	9-SEP-2024 14:17	<2.00	ug/L	2.0	15.5	SM3113B
Copper	9-SEP-2024 13:08	0.116	mg/L	0.05	1.3	SM3111B

Sample Location: R 7 5-1

Date Sampled: 09/05/24

Time Sampled: 09:52

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142044					
Lead	9-SEP-2024 14:23	<2.00	ug/L	2.0	15.5	SM3113B
Copper	9-SEP-2024 13:08	0.072	mg/L	0.05	1.3	SM3111B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

09/11/2024

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Richard F. Black Childrens Center
65 Horsehill Road
Cedar Knolls, NJ 07927
973-984-2255

www.sjwatertest.com
NJDEP Certified Lab # 08006

Sample Location: Woman R Date Sampled: 09/05/24 Time Sampled: 09:51

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142045					
Lead	9-SEP-2024 14:30	<2.00	ug/L	2.0	15.5	SM3113B
Copper	9-SEP-2024 13:08	0.174	mg/L	0.05	1.3	SM3111B

Sample Location: R 9 Date Sampled: 09/05/24 Time Sampled: 10:00

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142046					
Lead	9-SEP-2024 14:36	<2.00	ug/L	2.0	15.5	SM3113B
Copper	9-SEP-2024 13:09	0.103	mg/L	0.05	1.3	SM3111B

Sample Location: R 10 Date Sampled: 09/05/24 Time Sampled: 10:00

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142047					
Lead	9-SEP-2024 14:43	<2.00	ug/L	2.0	15.5	SM3113B
Copper	9-SEP-2024 13:12	0.086	mg/L	0.05	1.3	SM3111B

Sample Location: R 11 Date Sampled: 09/05/24 Time Sampled: 10:00

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142048					
Lead	9-SEP-2024 14:50	<2.00	ug/L	2.0	15.5	SM3113B
Copper	9-SEP-2024 13:12	0.084	mg/L	0.05	1.3	SM3111B

Sample Location: R 6 KS Date Sampled: 09/05/24 Time Sampled: 09:52

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142049					
Lead	9-SEP-2024 14:56	<2.00	ug/L	2.0	15.5	SM3113B
Copper	9-SEP-2024 13:12	0.106	mg/L	0.05	1.3	SM3111B

Sample Location: Mens R Date Sampled: 09/05/24 Time Sampled: 09:51

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142050					
Lead	9-SEP-2024 15:03	<2.00	ug/L	2.0	15.5	SM3113B
Copper	9-SEP-2024 13:13	0.134	mg/L	0.05	1.3	SM3111B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

09/11/2024

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Richard F. Black Childrens Center
65 Horsehill Road
Cedar Knolls, NJ 07927
973-984-2255

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: R 7 52

Date Sampled: 09/05/24

Time Sampled: 09:52

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142051					
Lead	9-SEP-2024 15:43	<2.00	ug/L	2.0	15.5	SM3113B
Copper	9-SEP-2024 13:13	0.064	mg/L	0.05	1.3	SM3111B

Sample Location: R 12

Date Sampled: 09/05/24

Time Sampled: 10:04

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142052					
Lead	9-SEP-2024 15:23	<2.00	ug/L	2.0	15.5	SM3113B
Copper	9-SEP-2024 13:10	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: R 15 T

Date Sampled: 09/05/24

Time Sampled: 10:10

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142053					
Lead	9-SEP-2024 15:49	<2.00	ug/L	2.0	15.5	SM3113B
Copper	9-SEP-2024 13:14	0.068	mg/L	0.05	1.3	SM3111B

Sample Location: R 13

Date Sampled: 09/05/24

Time Sampled: 10:06

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142054					
Lead	9-SEP-2024 15:56	<2.00	ug/L	2.0	15.5	SM3113B
Copper	9-SEP-2024 13:14	0.101	mg/L	0.05	1.3	SM3111B

Sample Location: R 1 T

Date Sampled: 09/05/24

Time Sampled: 10:15

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142055					
Lead	9-SEP-2024 16:02	<2.00	ug/L	2.0	15.5	SM3113B
Copper	9-SEP-2024 13:15	0.085	mg/L	0.05	1.3	SM3111B

Sample Location: R 1

Date Sampled: 09/05/24

Time Sampled: 10:15

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142056					
Lead	10-SEP-2024 10:14	<2.00	ug/L	2.0	15.5	SM3113B
Copper	9-SEP-2024 13:16	0.200	mg/L	0.05	1.3	SM3111B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

09/11/2024

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Richard F. Black Childrens Center
65 Horsehill Road
Cedar Knolls, NJ 07927
973-984-2255

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: R 2

Date Sampled: 09/05/24

Time Sampled: 10:15

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142057					
Lead	10-SEP-2024 10:34	<2.00	ug/L	2.0	15.5	SM3113B
Copper	9-SEP-2024 13:16	0.111	mg/L	0.05	1.3	SM3111B

Sample Location: R 11

Date Sampled: 09/05/24

Time Sampled: 10:04

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142058					
Lead	10-SEP-2024 10:40	<2.00	ug/L	2.0	15.5	SM3113B
Copper	9-SEP-2024 13:17	0.129	mg/L	0.05	1.3	SM3111B

Sample Location: R 11 S

Date Sampled: 09/05/24

Time Sampled: 10:00

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142059					
Lead	10-SEP-2024 10:47	<2.00	ug/L	2.0	15.5	SM3113B
Copper	9-SEP-2024 13:17	0.071	mg/L	0.05	1.3	SM3111B

Sample Location: R 20

Date Sampled: 09/05/24

Time Sampled: 09:56

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142060					
Lead	10-SEP-2024 10:53	<2.00	ug/L	2.0	15.5	SM3113B
Copper	9-SEP-2024 13:18	0.088	mg/L	0.05	1.3	SM3111B

Sample Location: R 6 T

Date Sampled: 09/05/24

Time Sampled: 09:50

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142061					
Lead	10-SEP-2024 11:00	<2.00	ug/L	2.0	15.5	SM3113B
Copper	9-SEP-2024 13:18	0.058	mg/L	0.05	1.3	SM3111B

Sample Location: R 8

Date Sampled: 09/05/24

Time Sampled: 09:56

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142062					
Lead	10-SEP-2024 11:06	<2.00	ug/L	2.0	15.5	SM3113B
Copper	9-SEP-2024 13:18	0.081	mg/L	0.05	1.3	SM3111B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

09/11/2024

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Richard F. Black Childrens Center
65 Horsehill Road
Cedar Knolls, NJ 07927
973-984-2255

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Kitchen

Date Sampled: 09/05/24 Time Sampled: 09:47

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142063					
Lead	10-SEP-2024 11:13	<2.00	ug/L	2.0	15.5	SM3113B
Copper	9-SEP-2024 13:19	<0.050	mg/L	0.05	1.3	SM3111B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

09/11/2024

Date

CHAIN OF CUSTODY RECORD

Customer: Richard F Blake Children Center
Contact: *ANN FOR INFO* **Ashley Kimberg** *CLAUDE WIMMERS*
Address: *25 SADDLE ROAD* **65 HORSEBILL**
Phone: Cedar Knolls, NJ 07927
Office: Fax:

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.siwaterest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
<i>WJ42033</i>	Field Reagent Blank	<i>9/15/24</i>	<i>0946</i>	D	1 x 250	HNO3*	First Draw Lead and Copper	
<i>WJ42034</i>	<i>KRICHAEN</i>	<i>9-5</i>	<i>0947</i>	D	1 x 250	HNO3*	First Draw Lead and Copper	
<i>WJ42035</i>	<i>RM 5</i>	<i>()</i>	<i>0950</i>	D	1 x 250	HNO3*	First Draw Lead and Copper	
<i>WJ42036</i>	<i>RM 4</i>	<i>()</i>	<i>0948</i>	D	1 x 250	HNO3*	First Draw Lead and Copper	
<i>WJ42037</i>	<i>RM 4-T</i>	<i>()</i>	<i>0948</i>	D	1 x 250	HNO3*	First Draw Lead and Copper	
<i>WJ42038</i>	<i>RM 5-T</i>	<i>()</i>	<i>0950</i>	D	1 x 250	HNO3*	First Draw Lead and Copper	
<i>WJ42039</i>	<i>RM 15</i>	<i>()</i>	<i>1010</i>	D	1 x 250	HNO3*	First Draw Lead and Copper	
<i>WJ42040</i>	<i>R-18</i>	<i>()</i>	<i>1010</i>	D	1 x 250	HNO3*	First Draw Lead and Copper	
<i>WJ42041</i>	<i>R-13T</i>	<i>()</i>	<i>1010</i>	D	1 x 250	HNO3*	First Draw Lead and Copper	
<i>WJ42042</i>	<i>R-14</i>	<i>()</i>	<i>1008</i>	D	1 x 250	HNO3*	First Draw Lead and Copper	

MATRIX ABBREVIATIONS: D=DRINKING WATER A=AQUEOUS S=SOIL SL=SLUDGE GW=GROUND WATER SWS=SURFACE WATER WW=WASTE WATER

Turnaround Time ___ SJWT Standard is 10-20 work days ___ Rush turnaround available upon request and lab approval _____	Report Format ___ Standard ___ NJ DEP Reduced Deliverables ___ NJ DEP Full Deliverables ___ Electronic Data Deliverables ___ PWTA Format	Comments/Special Instructions * HNO3 preserved upon receipt at laboratory	Cooler Temp <i>2.2</i> °C
	Properly Preserved Yes No	Yes No	Yes No

Sampled by: _____

Sampled by/Relinquished by: _____

Relinquished by: _____

Relinquished by: _____

Received by:	Time	Date	Time	Date	Time
<i>(Signature)</i>				<i>9/16/24</i>	<i>1155</i>
<i>(Signature)</i>				Date	Time
<i>(Signature)</i>				Date	Time

CHAIN OF CUSTODY RECORD

Customer: Richard F Blake Children Center
Contact: Ashley Kinberg
Address: 25 Saddle Road, 65 Horseville Rd
Phone: Cedar Knolls, NJ 07927
Office: Fax:

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwatertest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
WJ42042	RM-9-T	9-5	1000	D	1 x 250	HNO3*	First Draw Lead and Copper	
WJ42044	R-7 S-1		0952	D	1 x 250	HNO3*	First Draw Lead and Copper	
WJ42046	WOMAN R		0951	D	1 x 250	HNO3*	First Draw Lead and Copper	
WJ42046	R-9		1000	D	1 x 250	HNO3*	First Draw Lead and Copper	
WJ42047	R-10		1000	D	1 x 250	HNO3*	First Draw Lead and Copper	
WJ42048	R-11		1000	D	1 x 250	HNO3*	First Draw Lead and Copper	
WJ42049	R-6 KS		0952	D	1 x 250	HNO3*	First Draw Lead and Copper	
WJ42050	MENS. R		0951	D	1 x 250	HNO3*	First Draw Lead and Copper	
WJ42051	R-7 .52		0952	D	1 x 250	HNO3*	First Draw Lead and Copper	
WJ42052	R-12		1004	D	1 x 250	HNO3*	First Draw Lead and Copper	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE G: GROUND WATER S: SURFACE WATER W: WASTE WATER

Turnaround Time SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Comments/Special Instructions * HNO3 preserved upon receipt at laboratory	Cooler Temp 2.2 °C
	Properly Preserved Yes No		

Sampled by: (Print)	Received by: (Signature)	Time	Date	Time	Date
Sampled by/Relinquished by:	(Signature)	Time	Date	Time	Date
Relinquished by:	(Signature)	Time	Date	Time	Date
Relinquished by:	(Signature)	Time	Date	Time	Date

CHAIN OF CUSTODY RECORD

Customer: Richard F Blake Children Center
Contact: Ashley Kimberg
Address: 25 Saddle Road
 Cedar Knolls, NJ 07927
Phone:
Office:

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	g	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
WJ42053	R-15 T	9-5	1010	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
WJ42054	R-13		1006	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
WJ42055	R-1 -T		1015	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
WJ42056	R-1		1015	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
WJ42057	R-2		1015	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
WJ42058	R-11		1004	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
WJ42059	R-11 S		1000	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
WJ42060	R-20		0956	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
WJ42061	R-6 T		0950	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
WJ42062	R-8		0956	X		D	1 x 250	HNO3*	First Draw Lead and Copper	

MATRIX ABBREVIATIONS: D=DRINKING WATER A=AQUEOUS S=SOIL SL=SLUDGE GW=GROUND WATER SWS=SURFACE WATER WWW=WASTE WATER

Turnaround Time ___ SJWT Standard is 10-20 work days ___ Rush turnaround available upon request and lab approval _____	Report Format ___ Standard ___ NJ DEP Reduced Deliverables ___ NJ DEP Full Deliverables ___ Electronic Data Deliverables ___ PWTA Format	Comments/Special Instructions * HNO3 preserved upon receipt at laboratory	Cooler Temp 2.2 °C
		Properly Preserved Yes No	Yes No

Sampled by: _____

Sampled by/Relinquished by: _____
 (Signature)

Relinquished by: _____
 (Signature)

Relinquished by: _____
 (Signature)

Received by: _____ (Signature)	Date 9/6/24	Time 1155
Received by: _____ (Signature)	Date	Time
Received by: _____ (Signature)	Date	Time

CHAIN OF CUSTODY RECORD

Customer: Richard F Blake Children Center
Contact: Asntey Kinsberg
Address: 25 Saddle Roads
 Cedar Knolls, NJ 07927
Phone:
Office:

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
WJ2003	Kretzen	9-5	0947	D	1 x 250	HNO3*	First Draw Lead and Copper	
				D	1 x 250	HNO3*	First Draw Lead and Copper	
				D	1 x 250	HNO3*	First Draw Lead and Copper	
				D	1 x 250	HNO3*	First Draw Lead and Copper	
				D	1 x 250	HNO3*	First Draw Lead and Copper	
				D	1 x 250	HNO3*	First Draw Lead and Copper	
				D	1 x 250	HNO3*	First Draw Lead and Copper	
				D	1 x 250	HNO3*	First Draw Lead and Copper	
				D	1 x 250	HNO3*	First Draw Lead and Copper	
				D	1 x 250	HNO3*	First Draw Lead and Copper	

MATRIX ABBREVIATIONS: D=DRINKING WATER A=AQUEOUS S=SOIL SL=SLUDGE G=GROUND WATER S=SURFACE WATER W=WASTE WATER

Turnaround Time SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format Standard _____ NJ DEP Reduced Deliverables _____ NJ DEP Full Deliverables _____ Electronic Data Deliverables _____ PWTA Format _____	Comments/Special Instructions * HNO3 preserved upon receipt at laboratory	Cooler Temp 2.2 °C
	Properly Preserved Yes _____ No _____		

Sampled by: (Print) _____	Received by: (Signature) _____	Date 9/10/24	Time 11:55
Sampled by/Relinquished by: (Signature) _____	Received by: (Signature) _____	Date	Time
Relinquished by: (Signature) _____	Received by: (Signature) _____	Date	Time